

Test laboratory accredited according to ISO 17025 by the Swiss Accreditation Service SAS

Registration number

STS 0001

Swiss testing service




Report:	Electromagnetic compatibility	Report no:	19-MO-0006.E01
Test item description:	Redresseur de protection cathodique		
Applicant:	Indarco S.A., Route d'Echallens 39, 1041 Poliez-Pittet, SWITZERLAND		
Manufacturer:	Indarco S.A., Route d'Echallens 39, 1041 Poliez-Pittet, SWITZERLAND		
Model/Type reference:	K2000-12	Serial no:	1017-04
Trade mark:	Indarco	Date of tests:	January 16 and 17, 2019

Standards		Result
EN 61000-6-3:2007 + A1:2011 + AC:2012 IEC 61000-6-3:2006 /AMD1:2010	Electromagnetic compatibility (EMC) – Part 6-3: Generic standards – Emission standard for residential, commercial and light-industrial environments	Pass
EN 61000-6-4:2007 + A1:2011 IEC 61000-6-4:2006 /AMD1:2010	Electromagnetic compatibility (EMC) – Part 6-4: Generic standards – Emission standard for industrial environments	Pass

These results were achieved with modification(s) of the EUT documented § 8 of this report


Test performed by

Mr B. Itzcovich
EMC test-engineer




Report prepared by

Mr B. Itzcovich
EMC test-engineer



Report controlled and approved by

Mr J. Ding
EMC test-engineer



Rossens, January 21, 2019

(Issue Date)

__accredit_rap_2018-10-11.dotm

Main language : English

The present document results from tests on one specimen and does not prejudice to the conformity of all the manufactured products.

t:\dossiers\mo\2019\00xx\19-mo-0006_indarco\4 prüfberichte\19-mo-0006.e01_indarco_emission.docx